



NOTES:

1. TO BE FORMED WITH 2" x 6" BOARDS OR STEEL FORMS.
2. TOOLED JOINTS SHALL BE 1/2".
3. EXPANSION JOINTS SHALL BE 3/4" BITUMINOUS IMPREGNATED FIBERBOARD, AT DRIVEWAYS AND OTHER CONCRETE JOINTS.
4. PROVIDE BROOM FINISH.
5. D = 5" MINIMUM THICKNESS FOR ALL RESIDENTIAL WALKS & PATIOS
6. ALL SERVICE WALKS AND PATIOS SHALL BE BUILT PER THE VILLAGE OF WHEELING STANDARDS.
7. THE CONCRETE SHALL BE A 6 BAG MIX AND SHALL **NOT** CONTAIN CHLORIDE.
8. COMPACTED STONE BASE SHALL BE (CA-6, GRADE 8 OR GRADE 9) VIRGIN MATERIAL ONLY OR VILLAGE ENGINEER APPROVED EQUAL.



VILLAGE OF WHEELING
ENGINEERING DIVISION
2 COMMUNITY BOULEVARD
WHEELING, IL 60090
WWW.WHEELINGIL.GOV

SERVICE WALK AND PATIO STANDARDS

| VILLAGE OF WHEELING SPECIFICATIONS AND DETAILS | | REVISIONS | |
|---|--|-----------|-------------------------|
| FILE LOCATION | | W.F.H. | 10-04-04 AUTOCAD FILE |
| N:\ENGINEERING\STANDARDS\GENERAL | | S.W. | 03-23-05 COMMENTS BY GK |
| | | C.J.C. | 11-27-07 AUTOCAD FILE |